

# LICENCE

No. 20859 replaces No.19108

Issued to:

Applicant:

**Bruno Baldassari and F.LLI. S.p.A.**  
**Loc. Sardegna, Viale Europa, 118/120**  
**55013 LAMMARI-CAPANNORI (LUCCA)**  
**Italy**

Licensee:

**Bruno Baldassari and F.LLI. S.p.A.**  
**Loc. Sardegna, Viale Europa, 118/120**  
**55013 LAMMARI-CAPANNORI (LUCCA)**  
**Italy**



Product : cables for fixed wiring  
Trade name(s) : BALDASSARI  
Type(s)/model(s) : XGB

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 967

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 12/06/2018

ir. C. Lana,  
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed  
This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



## SPECIFICATION OF THE CERTIFIED PRODUCT

### Product data

Product	:	cables for fixed wiring
Trade name(s)	:	BALDASSARI
Type(s)/Model(s)	:	XGB
description	:	cable with copper conductors, unarmoured
insulating material	:	XLPE insulated and sheathed with G type halogen free compound
rated voltage Uo/U	:	0.6/1 kV
Fire propagation	:	minimum Cca-s1,d2,a1

### Additional information

Covered number of conductors (Round type) and cross sections

- 1-core : 50 mm<sup>2</sup> to 185 mm<sup>2</sup>
- 2-core: 1.5 mm<sup>2</sup> to 25 mm<sup>2</sup>
- 3 -core: 1.5 mm<sup>2</sup> to 50 mm<sup>2</sup>
- 4-core: 1.5 mm<sup>2</sup> to 50 mm<sup>2</sup>
- 5-core: 1.5 mm<sup>2</sup> to 25 mm<sup>2</sup>

## TESTS

### Test requirements

NBN HD 604:2016

### Test results

The test results are laid down in certification file ref.628990/01

### Remarks

This certificate is based on test reports ref. 603440.01a, 603440.01b, 603440.01c and 527C


**Conclusion**

The examination proved that all test requirements were met.

Checked by, project leader : Luigi Zanutto - 12/06/2018

Department Manager,  
Product Certification :

Certification Manager :

A handwritten signature in blue ink, followed by the date '2018-06-12'.

**FACTORY LOCATION(S)**

Bruno Baldassari and F.LLI. S.p.A.  
Loc. Sardegna, Viale Europa, 118/120  
55013 LAMMARI-CAPANNORI (LUCCA)  
Italy